



Environmental and Laboratory Services
 90 ½ West Blackwell St., Dover, New Jersey 07801
 (973) 989-0010 P, (973) 989-0156 F

Analytical Results

Date: December 8, 2017

Client: Netcong School
 Address: 26 College Road
 Netcong, NJ 07857

Project: Netcong School

Sample description: Drinking Water / 1st Draw / DWS7185-1
 Sample location: NS-WC-Fill- HW Music Room
 Sampled by: D. Mitchell
 Sample date: 12/04/17
 Time: 07:26
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	12/05/17	18:19	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS7185-2
 Sample location: NW-WC-Bubbler-HW Music Rm
 Sampled by: D. Mitchell
 Sample date: 12/01/17
 Time: 07:28
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	12/05/17	18:25	1	2 µg/L

Sample description: Drinking Water / 1st Draw / DWS7185-3
 Sample location: Field Blank
 Sampled by: D. Mitchell
 Sample date: 12/01/17
 Time: 07:26
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Dilution Factor	Reporting Limit
Lead	SM3113B	<2.00 µg/L	15 µg/L	12/05/17	18:32	1	2 µg/L

µg/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Susan VanVeen, Lab Manager
 NJ Laboratory Certification ID # 14013

Date